

Eligibility Requirements

Site-built or modular ¹ detached Dwellings ² (e.g., single-family homes and duplexes) and Townhouses ³ are eligible to participate in the ENERGY STAR Single-Family New Homes (SFNH) program. To determine the applicable SFNH program requirements, including the minimum Version and Revision, to which a home is eligible to be certified, visit www.energystar.gov/SFNHVersions.

Dwelling Units in certain low-rise multifamily buildings are also eligible to participate in the ENERGY STAR SFNH program if permitted prior to July 1, 2021. See Footnote 4 for details. 4

While primarily intended for new construction, existing homes (e.g., undergoing a substantial reconstruction or rehabilitation) are also eligible to participate in the ENERGY STAR SFNH program, with guidance available at: www.energystar.gov/RehabGuidance.

For information about other ENERGY STAR residential new construction programs, visit www.energystar.gov/newhomesrequirements.

Note that compliance with these requirements is not intended to imply compliance with all local code requirements. 5

Partnership, Training, and Credentialing Requirements

The following requirements must be met prior to certifying homes:

- Builders are required to sign an ENERGY STAR Partnership Agreement and complete the online Version 3 Builder Orientation, which can be found at www.energystar.gov/homesPA.
- HVAC installing contractors are required to be credentialed by an EPA-recognized HVAC Quality Installation Training and Oversight
 Organization (H-QUITO) for homes certified using Track B in Exhibit 2. An explanation of this process can be found at
 www.energystar.gov/newhomesHVAC.
- Energy Rating Companies (e.g., rater companies and Providers ⁶) are required to sign an ENERGY STAR Partnership Agreement, which can be found at www.energystar.gov/homesPA.
- Raters ⁷ are required to complete EPA-recognized training, which can be found at www.energystar.gov/newhomestraining, and be credentialed by a Home Certification Organization (HCO) ⁸ prior to completing inspections. Learn more at www.energystar.gov/hco.

ENERGY STAR Certification Process

- 1. The certification process provides flexibility to select a custom combination of measures for each home that is equivalent in performance to the minimum requirements of the ENERGY STAR Reference Design Home, Exhibit 1, as assessed through energy modeling. An EPA-recognized HCO's Approved Software Rating Tool shall automatically determine the ENERGY STAR ERI Target, which is the highest ERI value that each rated home may achieve to earn the ENERGY STAR. 9
- 2. Using the same software program, configure the preferred set of efficiency measures for the home to be certified and verify that the resulting ERI meets or exceeds the ENERGY STAR ERI Target, as determined in Step 1.
 - Note that, regardless of the measures selected, the Mandatory Requirements for All Certified Homes in Exhibit 2 are also required and impose certain constraints on the efficiency measures selected (e.g., insulation levels, insulation installation quality, window performance, duct leakage). Furthermore, on-site power generation may not be used to meet the ENERGY STAR ERI Target.
- 3. Construct the home using the measures selected in Step 2 and the Mandatory Requirements for All Certified Homes, Exhibit 2.
- 4. Using a Rater, verify that all requirements have been met in accordance with the Mandatory Requirements for All Certified Homes and with the inspection procedures for minimum rated features in ANSI / RESNET / ICC 301, Appendix B. ⁷ This will require a minimum of two inspections: one at pre-drywall and the other at final. All items shall be verified for each certified home and sampling protocols shall not be used. For modular homes, a Rater must verify any requirement in the plant not able to be verified on-site because a feature will be concealed prior to shipment. Finally, submit the home to the HCO for final certification and follow the HCO's certification and oversight procedures (e.g., quality assurance, recordkeeping, and reporting). The Rater is required to keep electronic or hard copies of the completed and signed Rater checklists and either an HVAC design report compliant with ANSI / RESNET / ACCA / ICC 310, and the National HVAC Design Supplement to Std. 310 for Dwellings & Units, for homes using Track A, or the National HVAC Design Report for homes using Track B.

The Rater must review all items on the Rater checklists to verify that each inspection checklist item has been met within program-defined tolerances. In the event that a Rater determines that a program requirement has not been met, the home cannot earn the ENERGY STAR until the item is corrected. If correction of the item is not possible, the home cannot earn the ENERGY STAR. In the event that an item on a Rater checklist cannot be inspected by the Rater, the home also cannot earn the ENERGY STAR. The only exceptions to this rule are in the Thermal Enclosure System Section of the National Rater Field Checklist, where the builder may assume responsibility for verifying a maximum of five items. This option shall only be used at the discretion of the Rater. When exercised, the builder's responsibility will be formally acknowledged by the builder signing the checklist for the item(s) that they verified.

In the event that a Rater is not able to determine whether a program requirement has been met (e.g., an alternative method of meeting a checklist requirement has been proposed), then the Rater shall consult their Provider. If the Provider also cannot make this determination, then the Rater or Provider shall report the issue to the EPA prior to project completion at: energystar.gov and will receive an initial response within 5 business days. If the EPA believes the current program requirements are sufficiently clear to determine whether the item in question has been met, then this guidance will be provided to the partner and enforced beginning with the house in question. In contrast, if the EPA believes the program requirements require revisions to make the intent clear, then this guidance will be provided to the partner but only enforced for homes permitted after a specified transition period after the release of the revised program requirements, typically 60 days in length.

This will allow the EPA to make formal policy decisions as partner questions arise and to disseminate these policy decisions through the <u>Policy Record</u> and the periodic release of revised program documents to ensure consistent application of the program requirements.

Revised 01/15/2025



Exhibit 1: ENERGY STAR Reference Design Home Summary 10

The following table summarizes the key efficiency features in the ENERGY STAR Reference Design Home, which is modeled to determine the ENERGY STAR ERI Target that a home must meet to be certified. While it is not mandatory to include these measures, if they are not used then other measures of equivalent efficiency will be needed to achieve the ENERGY STAR ERI Target.

In addition, note that the Mandatory Requirements for All Certified Homes, Exhibit 2, contain additional requirements such as total duct leakage limits, minimum allowed insulation levels, and minimum allowed fenestration performance. Therefore, the EPA recommends that partners review the documents in Exhibit 2 prior to selecting measures.

Climate Zone Type		Hot and Mixed Climates				Cold Climates				
2021 IECC Climate Zone 11	1	2	3	4	4C	5	6	7	8	
Thermal Enclosure										
Ceiling, Wall, & Floor Insulation Grade					I					
Ceiling Insulation	R-30	R-49	R-49	R-60	R-60	R-60	R-60	R-60	R-60	
Wall Insulation: Cavity + Continuous	R-13	R-13	R-20	R-20 + R-5	R-20 + R-5	R-20 + R-5	R-20 + R-5	R-20 + R-5	R-20 + R-5	
Frame Floor Insulation	R-13	R-13	R-19	R-19	R-30	R-30	R-30	R-38	R-38	
Slab Insulation & Depth	None	None	R-10 2ft	R-10 4ft	R-10 4ft	R-10 4ft	R-10 4ft	R-10 4ft	R-10 4ft	
Window U-Factor	0.40	0.40	0.30	0.30	0.27	0.27	0.27	0.27	0.27	
Window SHGC	0.25	0.25	0.25	0.30	0.30	0.30	0.30	0.30	0.30	
Door (U-Factor / SHGC)	Opaque: U-Factor: 0.17 / SHGC: Any; ≤½ lite Door: U-Factor: 0.25 / SHGC: 0.25; >½ lite Door: U-Factor: 0.30									
>½ lite Door (SHGC)	0.25	0.25	0.25	0.40	0.40	0.40	0.40	0.40	0.40	
Heating and Cooling Systems										
Air Conditioning (SEER2)	15.2	15.2	15.2	15.2	13.3	13.3	13.3	13.3	13.3	
Gas Furnace (AFUE)	80	80	80	90	95	95	95	95	95	
Gas Boiler (AFUE)	80	80	80	90	95	95	95	95	95	
Heat Pump (HSPF2 / SEER2)	7.8 / 15.2									
HVAC Grade	Airflow Grade: II; Watt Draw Efficiency Grade: II; Refrigerant Grade: III									
Thermostat Type	Programmable									
Duct Location, Leakage, & Insulation	Location: 100% Conditioned Space; Leakage to Outside: 0 CFM; Insulation: Not Present									
Infiltration										
Infiltration Rate (ACH50)	3									
Water Heating										
Gas: Efficiency (UEF) & Capacity (Gal.)	0.90 & 0 (Instantaneous)									
Electric: Efficiency (UEF) & Capacity (Gal.)	2.20 & 60									
Lighting & Appliances										
Lighting	100% LED Lighting									
Refrigerators, Dishwashers, Ceiling Fans	Efficiency Equal to ENERGY STAR Product (Labeled product recommended, but not required)									

Revised 01/15/2025



Two tracks are provided for satisfying the mandatory requirements for all certified homes, Exhibit 2. Track A - HVAC Grading utilizes ANSI / RESNET / ACCA / ICC 310 ¹², a standard for grading the installation of HVAC systems. Track B - HVAC Credential utilizes an HVAC contractor credentialed by an EPA-recognized H-QUITO. Either track may be selected, but all requirements within that track must be satisfied for the home to be certified.

Exhibit 2: Mandatory Requirements for All Certified Homes

Party Responsible	Mandatory Requirements				
Requirements Applicable to Track A & B					
Rater	 Completion of SFNH National Rater Design Review Checklist, Version 3.1 / 3.2 / 3.3 Completion of SFNH National Rater Field Checklist, Version 3.1 / 3.2 / 3.3 				
Requirements Only Applicable to Track A - HVAC Grading ¹²					
HVAC System Designer	Completion of an HVAC design report compliant with ANSI / RESNET / ACCA / ICC 310, plus the SFNH / MFNC National HVAC Design National HVAC Design Supplement to Std. 310 for Dwellings & Units, All Versions.				
HVAC Installing Contractor	While the HVAC contractor plays a critical role in properly installing and commissioning a system, the Rater is the party responsible for assessing its installation quality, per ANSI / RESNET / ACCA / ICC 310. However, the installing contractor may be required to provide documentation to support the Rater's assessment (e.g., regarding the refrigerant system).				
Requirements Only Applicable to Track B - HVAC Credential					
HVAC System Designer	Completion of SFNH National HVAC Design Report, Version 3.1 / 3.2 / 3.3				
HVAC Installing Contractor	Completion of SFNH National HVAC Commissioning Checklist, Version 3.1 / 3.2 / 3.3				

Footnotes:

- 1. A modular home is a prefabricated home that is made of multiple modules or sections that are manufactured and substantially assembled in a manufacturing plant. These pre—built sections are transported to the building site and constructed by a builder to meet all applicable building codes for site—built homes.
- 2. A Dwelling, as defined by ANSI / RESNET / ICC 301, is any building that contains one or two Dwelling Units used, intended, or designed to be built, used, rented, leased, let or hired out to be occupied, or that are occupied for living purposes. ANSI / RESNET / ICC 301 defines a Dwelling Unit as a single unit providing complete independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking, and sanitation.
- 3. A Townhouse, as defined by ANSI / RESNET / ICC 301, is a single-family Dwelling Unit constructed in a group of three or more attached units in which each unit extends from the foundation to roof and with open space on at least two sides.
- 4. If permitted prior to July 1, 2021, the following are also eligible to participate in the ENERGY STAR SFNH program:
 - Dwelling units ² in any multifamily building with 4 units or fewer; OR
 - Dwelling units in multifamily buildings with 3 stories or fewer above-grade; OR
 - Dwelling units in multifamily buildings with 4 or 5 stories above-grade where dwelling units occupy 80% or more of the occupiable square footage of the building. When evaluating mixed—use buildings for eligibility, exclude commercial / retail space when assessing whether the 80% threshold has been met.

Any above-grade story with 20% or more occupiable space, including commercial space, shall be counted towards the total number of stories for the purpose of determining eligibility to participate in the program. The definition of an 'above-grade story' is one for which more than half of the gross surface area of the exterior walls is above-grade. All below-grade stories, regardless of type, shall not be included when evaluating eligibility.

Per ASHRAE 62.2-2010, occupiable space is any enclosed space inside the pressure boundary and intended for human activities or continual human occupancy, including, but not limited to, areas used for living, sleeping, dining, and cooking, toilets, closets, halls, storage and utility areas, and laundry areas.

- 5. While certification will result in compliance with many code requirements, a Rater is not responsible for ensuring that all code requirements have been met prior to certification. For more information about how these program requirements help satisfy code requirements, visit: www.energystar.gov/newhomesquidance. In the event that a code requirement, a manufacturer's installation instructions, or an engineering document conflicts with a requirement of the ENERGY STAR program, then the conflicting requirement within these program requirements shall not be met. Certification shall only be allowed if the Rater has determined that no equivalent option is available that could meet the conflicting requirement. Note that a home must still meet its ENERGY STAR ERI Target. Therefore, other efficiency measures may be needed to compensate for the omission of the conflicting requirement.
- The term 'Provider' refers to an Approved Rating Provider, as defined by ANSI / RESNET / ICC 301, that is approved by an HCO.
- 7. The term 'Rater' refers to the person(s) completing the third-party verification required for certification. The person(s) shall: a) be a Certified Rater or Approved Inspector, as defined by ANSI / RESNET / ICC 301, or an equivalent designation as determined by an HCO; and, b) have attended and successfully completed an EPA-recognized training class. See www.energystar.gov/newhomestraining.



- 8. HCOs are independent organizations recognized by the EPA to implement an ENERGY STAR certification program for single-family and multifamily homes and apartments using an Energy Rating Index (ERI) compliance path. Learn more and find a current list of HCOs at www.energystar.gov/hco.
- 9. The software program shall automatically determine (i.e., without relying on a user-configured ENERGY STAR Reference Design) this target for each rated home by following the National ERI Target Procedure, Version 3.2 (Rev. 14), available at www.energystar.gov/newhomesrequirements.
- 10. While the corresponding ERI Target Procedure specifies air conditioners and heat pumps using SEER and HSPF, in this document they have been <u>converted</u> to the current rating metrics, SEER2 and HSPF2, assuming a ducted split system. Note that the efficiency levels of ENERGY STAR certified products aligned with these product specifications when this Version was first released. These efficiency features form the basis of the ENERGY STAR ERI target, regardless of any subsequent revisions to ENERGY STAR certified product specifications. The EPA recommends, but does not require, that current ENERGY STAR products be included in ENERGY STAR homes. For current ENERGY STAR products, visit www.energystar.gov/products.
- 11. 2021 IECC Climate Zone designations, as defined and illustrated in <u>Section R301</u> of the code, are used to configure the ENERGY STAR Reference Design Home. Note that some locations have shifted to a different Climate Zone in the 2021 IECC compared to prior editions.
- 12. Track A HVAC Grading shall use ANSI / RESNET / ACCA / ICC 310 including all Addenda and Normative Appendices, with new versions and Addenda implemented according to the schedule defined by the HCO that the home is being certified under.

Revised 01/15/2025